



TEST REPORT

N° 1854

CUSTOMER ORDER N°	DATE CERTIFIED	NET WEIGHT SHIPPED	CUSTOMER N°
PO # 293	October 27, 2016	0.52 TM	E281
PRODUCT: COPPER BARS - BARRAS DE COBRE			
COPPER UNS N°	SIZE	FORM	
C11000	1/4 x1 1/2 x 5.00 FRE	FRE	inch x inch x m
CERT. TO: COMETA S.A.S.			
ADDRESS CALLE 45 NO. 1E-92 CALI COLOMBIA			

TESTS

DESCRIPTION OF GOODS		CHEMICAL COMPOSITION	
ESPECIF.	ASTM B187	ELEMENT	% Cu
		PURITY	99.99
TEMPER	H02	CHEMICAL ELECTRIC TEST	
NBR. OF PIECES	50	ELEMENT	VALUE
		HARDNESS	HRF 85.3
		CONDUCTIVITY	IACS 100.9
		BEND TEST	120° GOOD
HEAT / NUMBER	976/11000-1/4 x1 1/2 x 5.00 FRE		
COMMENTS	BUNDLES to		

- This Certificate is issued to guarantee that this material conforms to your Purchase Order in all respects. Those items marked with an asterisk (*) are only reference


Eloy Vasquez P.

Responsible of
Quality Assurance

Quality Control Chief

Date: October 27, 2016